

# Owner's Manual

## OmniSmart™ & SmartPro® USB

120V Input/Output, Line-Interactive UPS Systems



Register on-line today for a chance to win  
a FREE Tripp Lite product!  
[www.tripplite.com/warranty](http://www.tripplite.com/warranty)



### Important Safety Instructions

2

### Quick Installation

3

### Basic Operation

4

### Storage & Service

7

### Specifications

8

### Español

9

### Français

17



1111 W. 35th Street Chicago, IL 60609 USA  
Customer Support: (773) 869-1234 • [www.tripplite.com](http://www.tripplite.com)

Copyright © 2003 Tripp Lite. All rights reserved.  
OmniSmart™ is a trademark of Tripp Lite. SmartPro® is a registered trademark of Tripp Lite.



## SAVE THESE INSTRUCTIONS

This manual contains instructions and warnings that should be followed during the installation, operation and storage of all Tripp Lite UPS Systems. Failure to heed these warnings will void your warranty.

## UPS Location Warnings

- Install your UPS indoors, away from excess moisture or heat, dust or direct sunlight.
- For best performance, keep the indoor temperature between between 32° F and 104° F (0° C and 40° C).
- Leave adequate space around all sides of the UPS for proper ventilation.

## UPS Connection Warnings

- Connect your UPS directly to a properly grounded AC power outlet. Do not plug the UPS into itself; this will damage the UPS.
- Do not modify the UPS's plug, and do not use an adapter that would eliminate the UPS's ground connection.
- Do not use extension cords to connect the UPS to an AC outlet. Your warranty will be voided if anything other than Tripp Lite surge suppressors are used to connect your UPS to an outlet.
- If the UPS receives power from a motor-powered AC generator, the generator must provide clean, filtered, computer-grade output.

## Equipment Connection Warnings

- Do not use Tripp Lite UPS Systems for life-support appliances in which a malfunction or failure of a Tripp Lite UPS System could cause failure or significantly alter the performance of a life-support device.
- Do not connect surge suppressors or extension cords to the output of your UPS. This may damage the UPS and will void the surge suppressor and UPS warranties.


## Battery Warnings

- Your UPS does not require routine maintenance. Do not open your UPS for any reason. There are no user-serviceable parts inside.
- Battery replacement must be performed by qualified service personnel. Because the batteries present a risk of electrical shock and burn from high short-circuit current, observe proper precautions. Unplug and turn off the UPS before performing battery replacement. Use tools with insulated handles, and replace the existing batteries with the same number and type of new batteries (Sealed Lead-Acid). Do not open the batteries. Do not short or bridge the battery terminals with any object.
- The UPS batteries are recyclable. Refer to local codes for disposal requirements, or in the USA only call 1-800-SAV-LEAD or 1-800-8-BATTERY (1-800-8-228-8379) or visit [www.rbrc.com](http://www.rbrc.com) for recycling information. Do not dispose of the batteries in a fire.
- Do not attempt to add external batteries.

# Quick Installation


## 1 Connect your UPS to an electrical outlet.

Your UPS will run a self-test after it is plugged in. See Basic Operation to understand the results of its self-test.





## 2 Plug your computer, monitor and other equipment into the UPS system.

Your UPS is designed to support only computer equipment. You will overload your UPS if you connect high power draw equipment such as household appliances or laser printers to outlets providing UPS battery backup. Select models feature special outlets (clearly labeled on the rear panel) which provide surge-only (not battery backup) protection designed for laser printers and other heavy-draw devices.



## 3 Select UPS Operating Mode.\*

Press the **ON/OFF** button to toggle your UPS between the **UPS** (“” LED lit) and the **CHARGE ONLY** (“” LED flashing) modes. Choose the operating mode based on your location:

USA, Canada & Western Europe:

- Leave the UPS in the **UPS** mode at all times.


All other countries:

- Put the UPS in the **CHARGE ONLY** mode when you are not using connected equipment.

*(WARNING! When set to “CHARGE ONLY,” the UPS will not provide battery backup during a blackout or brownout)*

- Put the UPS in the **UPS** mode when you are using connected equipment.

*\*See Basic Operation section for a complete explanation of each mode.*



## Quick Installation *optional*


These connections are optional. Your UPS will function properly without these connections.

### 1 Phone Line/Network Line Surge Suppression

(Select models only)


Your UPS has either jacks which protect against surges over a phone or network dataline or jacks which protect against surges on a phone line only. See Specifications to determine which jacks your model has.

Using telephone cords or network data cables as appropriate, connect your wall jack to the UPS jack marked “IN.” Connect your equipment to the UPS jack marked “OUT.” Make sure the equipment you connect to the UPS’s jacks is also protected against surges on the AC line.



### 2 USB Communications

Use any USB cable to connect the USB port of your computer to the USB port of your UPS. Download the PowerAlert UPS monitoring software program appropriate for your operating system from [www.tripplite.com](http://www.tripplite.com) and install it on your computer.



## Basic Operation


### Buttons


Use the **ON/OFF** button to do three things:



**Switch your UPS's Operating Mode:** While your UPS is plugged into a live AC outlet, press the **ON/OFF** button and hold it until you hear a beep (about 2 seconds) to toggle between the following operating modes. Choose your UPS's operating mode based on the regional guidelines in Step 3 of the Quick Installation section.

- **UPS Mode:** ENABLES battery backup. **UPS Conditions:** The UPS charges its battery and supplies power at its receptacles when it is receiving utility line power. If utility power fails, the UPS provides power from its batteries. The “~” indicator light is lit. **Setting Advantages:** Provides battery backup during blackouts or brownouts.

- **CHARGE ONLY Mode:** DISABLES battery backup. **UPS Conditions:** The UPS charges its battery and supplies power at its receptacles when it is receiving utility line power. The “” indicator light is flashing. **Setting Advantages:** Continues to charge the battery when power is present while turning OFF the inverter to prevent battery depletion during power outages when equipment is not in use.

**Cold-Start Your UPS:** You may “cold start” your UPS and use it as a stand-alone power source when utility power is not present, providing that the UPS battery is charged. To “cold start” your UPS, press and hold the **ON/OFF** button until you hear a beep (about 2 seconds), then release it. The “” indicator light will illuminate and AC power inverted from stored battery power will be provided at its receptacles.



**Shut Down Your UPS:** Press and hold the **ON/OFF** button when AC line power is absent (i.e. during a blackout, or when the UPS is unplugged) to deactivate your UPS.

Use the **MUTE/TEST** button to do two things:



**Silence the UPS On-Battery Alarm:** Press and hold this button to silence the UPS On-Battery alarm, a series of short beeps followed by a brief pause that is activated when the UPS is providing AC power from battery. Note: When the battery is nearly depleted, the Low Battery alarm—a continuous beep that cannot be silenced—will alert you to immediately shut down connected equipment.

**Run a Self-Test:** Your UPS performs a self-test whenever it is first plugged in. To have it run a self-test at another time, leave your connected equipment on. With your UPS plugged in and in the **UPS** mode, press and hold this button until you hear a beep (about 2 seconds) then release it.

**Results of a Self-Test:** All the LEDs\* will be lit and the UPS will emit several short beeps as it momentarily switches to battery to test its charge and load capacity. The test will last at most 10 seconds. If the inverter is overloaded, the “” LED (on select models) will stay lit and the UPS will continue to beep after the test; if this happens, remove some of the load and run the self-test again. If the batteries seem weak, the “” LED will stay lit and the UPS will continue to beep after the test; if this happens, let UPS charge its batteries for 12 hours and repeat the test. If the condition persists, contact Tripp Lite for service. **CAUTION:** Do not unplug your UPS to test its batteries. This will remove safe electrical grounding and may introduce a damaging surge into your network connections.

\* Depending on the condition of the incoming voltage the “VOLTAGE REGULATION” LED may or may not be lit.

## Basic Operation *continued*

### Indicator Lights


All Indicator Light descriptions apply when the UPS is plugged into an AC outlet and turned on.



**LINE POWER:** This green light will turn ON whenever your UPS is receiving normal AC line power. It will flash while the UPS is in **CHARGE ONLY** mode to indicate that the UPS will not provide battery backup during a blackout or brownout.



**BATTERY POWER:** This yellow light will turn ON when your UPS is providing your equipment with battery power.



**BATTERY CHARGE:** This red light will turn ON continuously after the UPS runs a self-test to indicate that the UPS's battery is weakly charged. If it remains lit after you have allowed the UPS to charge for twelve hours and have run a second self-test, contact Tripp Lite for service.




**OVERLOAD (Select models only):** This red light will turn ON continuously when the UPS is providing power from battery or after the UPS runs a self-test to indicate that the UPS's inverter is overloaded. If it lights up, immediately remove some of the equipment connected to the UPS and run a self-test. Large overloads may cause your UPS to shut down.




**VOLTAGE REGULATION (Select models only):** This light will turn ON when your UPS is automatically correcting high or low utility line voltage. The UPS will also click gently when this automatic voltage regulation is operating. These are both normal functions of your UPS, and no action is required on your part.

### Other UPS Features



**AC Receptacles:** "UPS/Surge" receptacles are used to provide your connected equipment with AC line power during normal operation and battery power during blackouts and brownouts. They also protect your equipment against damaging surges and line noise. "Surge-only" receptacles (identified on the back of select UPS models) are used to provide peripherals with surge protection without committing precious battery power to support them during blackouts.




**Telephone/Network Protection Jacks (Select models only):** These jacks protect your equipment against surges over a telephone or data line. Your UPS has either jacks which can be used with both phone and data lines, or jacks which can be used with phone lines only. See Specifications to determine what kind of jacks your UPS has. Connecting your equipment to these jacks is optional. Your UPS will work properly without this connection.

## Basic Operation *continued*



**USB Port:** The USB port connects your UPS to any USB workstation or server. Using this port, your UPS can communicate line-fail and low-battery status to your computer. Use with Tripp Lite software and any USB cable to automatically save open files and shut down equipment during a blackout. Contact Tripp Lite Customer Support or consult your power protection software manual for more information.



**Battery Replacement Door:** Under normal conditions, the original battery in your UPS will last several years. Battery replacement should be performed only by qualified service personnel. Refer to “Battery Warnings” in the Safety section on page 2.



**Power Sensitivity/Lowline Adjustment:** This dial is normally set fully counterclockwise, which enables the UPS to protect against waveform distortions in its AC input. When such distortion occurs, the UPS will normally switch to providing PWM sinewave power from its battery reserves for as long as the distortion is present. In some areas with poor utility power or where the UPS's input power comes from a backup generator, frequent brownouts and/or chronic waveform distortion could cause the UPS to switch to battery too often, draining its battery reserves. You may be able to reduce how often your UPS switches to battery due to waveform distortion or brownouts by experimenting with different settings for this dial. As the dial is turned clockwise, the UPS becomes more tolerant of variations in its input power's AC waveform and reduces the voltage point at which it switches to battery. NOTE: The further the dial is adjusted clockwise, the greater the degree of waveform distortion and the lower the input voltage the UPS will allow to pass to connected equipment. When experimenting with different settings for this dial, operate connected equipment in a safe test mode so that the effect on the equipment of any waveform distortions in the UPS's output can be evaluated without disrupting critical operations. The experiment should last long enough to assure that all expected line conditions are encountered.

**Automatic Voltage Regulation:** During brownouts, your UPS will automatically correct low AC line voltage. When automatic voltage regulation is operating, your UPS may be heard to click gently. This is a normal, automatic operation of your UPS, and no action is required on your part.

## Storage & Service

### Storage

All connected equipment should be turned off, then disconnected from the UPS to avoid battery drain. Unplug your UPS from its AC receptacle, then press and hold its ON/OFF button to deactivate it. Your UPS is now ready for storage. If you plan on storing your UPS for an extended period of time, fully recharge the UPS batteries once every three months by plugging the UPS into a live AC outlet and letting the UPS charge for 4 to 6 hours. If you leave your UPS batteries discharged for an extended period of time, they will suffer a permanent loss of capacity.

### Service

If returning your UPS for service, contact your local Tripp Lite dealer or distributor. They will refer you to a service center. Please carefully pack the UPS using the ORIGINAL PACKING MATERIAL that came with the unit. Enclose a letter describing the symptoms of the problem. If the UPS is within the warranty period, enclose a copy of your sales receipt.

# Specifications

Tripp Lite has a policy of continuous improvement. Specifications are subject to change without notice.

## SmartPro® USB UPS Systems

Model: Series:	SMART500USB 163620U1	SMART550USB AGSM500USBKJR6	SMART700USB AGOM1000USBKSR6
Input Voltage/Frequency:	120V/60 Hz	120V/60 Hz	120V/60 Hz
On-Line Input Voltage Range:	83 - 147 volts	83 - 147 volts	83 - 147 volts
Output Capacity (VA/Watts):	500/300	550/300	700/450
Battery Runtime (Half Load/Full Load) Minutes:	17/5	17/5	20/6
Battery Recharge Time:	2-4 hrs.	2-4 hrs.	2-4 hrs.
Approvals:	UL, cUL, NOM, FCC-B	UL, cUL, NOM, FCC-B	UL, cUL, NOM, FCC-B
Tel/Fax/Data Protection:	1-line tel/DSL	1-line tel/DSL	1-line tel/DSL/Ethernet

## OmniSmart™ UPS Systems

Model: Series:	OMNISMART300 163550U	OMNISMART500 AGSM500USBKJR6	OMNISMART700 AGOM700USBKSR61	OMNISMART850 AGOM1050PJR61
Input Voltage/Frequency:	120V/60 Hz	120V/60 Hz	120V/60 Hz	120V/60 Hz
On-Line Input Voltage Range:	83-147 volts	75 - 147 volts	75 - 147 volts	75 - 147 volts
Output Capacity (VA/Watts):	300/180	500/300	700/425	850/600
Battery Runtime (Half Load/Full Load) Minutes:	17/5	17/5	22/7	26/9
Battery Recharge Time:	2-4 hrs.	2-4 hrs.	2-4 hrs.	2-4 hrs.
Approvals:	UL, cUL, NOM, FCC-B	UL, cUL, NOM, FCC-B	UL, cUL, NOM, FCC-B	UL, cUL, NOM, FCC-B
Tel/Fax/Data Protection:	1-line tel/DSL	1-line tel/DSL	1-line tel/DSL/Ethernet	None

Model: Series:	OMNISMART1000VS AGOM1000USBKSR6	OMNISMART1050 AGOM1050PJR61	OMNISMART1400 AGOM1400PSR61
Input Voltage/Frequency:	120V/60 Hz	120V/60 Hz	120V/60 Hz
On-Line Input Voltage Range:	83 - 147 volts	75 - 147 volts	75 - 147 volts
Output Capacity (VA/Watts):	1000/500	1050/705	1400/940
Battery Runtime (Half Load/Full Load) Minutes:	17/5	23/7	24/8
Battery Recharge Time:	2-4 hrs.	2-4 hrs.	2-4 hrs.
Approvals:	UL, cUL, NOM, FCC-B	UL, cUL, NOM, FCC-B	UL, cUL, NOM, FCC-B
Tel/Fax/Data Protection:	1-line tel/DSL	None	None

**ALL UNITS:** Output Waveform Line Mode (filtered sine wave); Output Waveform Battery Mode (PWM sine wave); AC Surge Suppression (exceeds IEEE 587 Cat. A & B standards); AC Noise Attenuation (>40 dB at 1MHz); AC Protection Modes (H to N, H to G, N to G).

**FCC RADIO/TV INTERFERENCE NOTICE:** Note: This equipment has been tested and found to comply with the limits for a Class B digital device, pursuant to Part 15 of the FCC Rules. These limits are designed to provide reasonable protection against harmful interference in a residential installation. This equipment generates, uses and can radiate radio frequency energy, and if not installed and used in accordance with the instruction manual, may cause interference to radio communications. However, there is no guarantee that interference will not occur in a particular installation. If this equipment does cause harmful interference to radio or television reception, which can be determined by turning the device off and on, the user is encouraged to try to correct the interference using one or more of the following measures: reorient or relocate the receiving antenna; increase the separation between the equipment and receiver; connect the equipment into an outlet on a circuit different from that which the receiver is connected; consult the dealer or an experienced radio/television technician for help. The user must use shielded cables and connectors with this product. Any changes or modifications to this product not expressly approved by the party responsible for compliance could void the user's authority to operate the equipment.

### CONSUMER INFORMATION AND FCC REQUIREMENTS (U.S. only):

1. This equipment complies with Part 68 of the FCC rules. On the top or bottom of this equipment is a label that contains, among other information, the FCC registration number for this equipment. If requested, provide this information to your telephone company.
2. If your Fax/Modem Protector causes harm to the telephone network, the telephone company may temporarily discontinue your service. If possible, they will notify you in advance. But if advance notice isn't practical, you will be notified as soon as possible. You will be advised of your right to file a complaint with the FCC.
3. Your telephone company may make changes in its facilities, equipment, operations or procedures that could affect the operation of your equipment. If they do, you will be given advance notice so as to give you an opportunity to maintain uninterrupted service.
4. If you experience trouble with this Fax/Modem Protector, please contact Tripp Lite Customer Support, 1111 W. 35th Street, Chicago, Illinois 60609; Phone (773) 869-1234 for repair/warranty information. The telephone company may ask you to disconnect this equipment from the network until the problem has been corrected or you are sure that the equipment is not malfunctioning.
5. This equipment may not be used on coin service provided by the telephone company. Connection to party lines is subject to state tariffs. (Contact your state public utility commission or corporation for information.)

**EQUIPMENT ATTACHMENT LIMITATIONS (Models with the Industry Canada label in Canada only):** NOTICE: The Industry Canada label identifies certified equipment. This certification means that the information meets the telecommunications network protective, operational and safety requirements as prescribed in the appropriate Terminal Equipment Technical Requirements Document(s). The Department does not guarantee the equipment will operate to the user's satisfaction.

Before installing this equipment, users should ensure that it is permissible to be connected to the facilities of the local telecommunications company. The equipment must also be installed using an acceptable method of connection. The customer should be aware that the compliance with the above conditions might not prevent degradation of service in some situations.

Repairs to certified equipment should be coordinated by a representative designated by the supplier. Any repairs or alterations made by the user to this equipment, or equipment malfunctions, may give the telecommunications company cause to request the user to disconnect the equipment.

Users should ensure for their own protection that the electrical ground connections of the power utility, telephone lines and internal metallic water pipe system, if present, are connected together. This precaution may be particularly important in rural areas. Caution: Users should not attempt to make connections themselves, but should contact the appropriate electric inspection authority or electrician, as appropriate.

### Ultimate Lifetime Insurance

Tripp Lite warrants, for the lifetime of the product, (at Tripp Lite's option) to repair or replace (on a pro rata basis) directly connected equipment that is damaged due to power transients while properly connected to Tripp Lite products offering the Ultimate Lifetime Insurance Policy. Power transients include spikes and surges on the AC power, data or telephone lines that the Tripp Lite products have been designed to protect against (as recognized by industry standards).

**AC Power Line Transients:** To claim damages, the Tripp Lite product must be plugged into a properly wired and grounded outlet. No extension cords or other electrical connections may be used. The installation must comply with all applicable electrical and safety codes set forth by the National Electrical Code (NEC). Except as provided above, this warranty does not cover any damage to properly connected electronic equipment resulting from a cause other than an "AC power transient." If user meets all of the above requirements, Tripp Lite will repair or replace (at Tripp Lite's option) equipment up to the specified value (See Ultimate Lifetime Insurance Policy Limits). No coverage is allowed for damage entering from telephone or data lines, unless they are separately protected, as described below.

**Telephone and Data Line Transients:** Tripp Lite will repair or replace directly connected equipment that is damaged by transients on telephone and/or data lines only when all such paths are protected by a Tripp Lite protection product(s) and the AC power (utility line) is simultaneously protected by a Tripp Lite power protection device (UPS, surge suppressor or line conditioner) with Ultimate Lifetime Insurance coverage. Additional telephone and/or data line connected devices downstream must have their own telephone and/or data line protection.

Reimbursement dollar limits will be equal to that of the Tripp Lite power protection product. Coverage is excluded where a suitable environment for the protection device is not provided, including, but not limited to, lack of a proper safety ground. Telephone service equipment must also include a properly installed and operating "primary protection" device at the telephone service entrance (such devices are normally added during telephone line installation).

All above warranties are null and void if the Tripp Lite product has been improperly installed, tampered with or altered in any way, or if the connected equipment was not used under normal operating conditions or in accordance with any labels or instructions. All claims under this warranty must be submitted in writing to Tripp Lite within 30 days of the occurrence or the claim will not be considered. This warranty does not include damage resulting from accident or misuse, and applies to the domestic (USA & Canada) use of these products only.

Tripp Lite reserves the right to determine whether the damage to the connected equipment is due to malfunction of the Tripp Lite product by requesting the equipment in question be sent to Tripp Lite for examination. This policy is above and beyond, only to the extent needed, of that provided by any coverage of connected equipment provided by other sources, including, but not limited to, any manufacturer's warranty and/or any extended warranties.

**EXCEPT AS PROVIDED ABOVE, TRIPP LITE MAKES NO WARRANTIES, EXPRESS OR IMPLIED, INCLUDING WARRANTIES OF MERCHANTABILITY AND FITNESS FOR A PARTICULAR PURPOSE.** Some states do not permit limitation or exclusion of implied warranties; therefore, the aforesaid limitation(s) or exclusion(s) may not apply to purchaser.

**EXCEPT AS PROVIDED ABOVE, IN NO EVENT WILL TRIPP LITE BE LIABLE FOR DIRECT, INDIRECT, SPECIAL, INCIDENTAL OR CONSEQUENTIAL DAMAGES ARISING OUT OF THE USE OF THIS PRODUCT, EVEN IF ADVISED OF THE POSSIBILITY OF SUCH DAMAGE.** Specifically, Tripp Lite is not liable for any costs, such as lost profits or revenue, loss of equipment, loss of use of equipment, loss of software, loss of data, costs of substitutes, claims by third parties or otherwise. Coverage also does not apply to connected medical and industrial equipment.

To receive service under this warranty, you must be the original purchaser/user of the product in question. You must obtain a Returned Material Authorization (RMA) number from Tripp Lite. Products must be returned to Tripp Lite with transportation charges prepaid and must be accompanied by a brief description of the problem encountered and proof of date and place of purchase.

**Note on Labeling: Two symbols are used on the label. V~ : AC Voltage V---: DC Voltage**





1111 W. 35th Street, Chicago, IL 60609 USA  
773.869.1234 (USA) • 773.869.1212 (International)  
[www.triplite.com](http://www.triplite.com)